

AS Tallinna Vesi Operational Indicators 2000-2015

AS Tallinna Vesi tegevusnäitajad 2000-2015

		2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
POTABLE WATER	JOOGIVESI																
Water Quality at customers	Veekvaliteet kliendi juures	43,50%	63,70%	79,30%	85,34%	92,42%	97,61%	96,67%	97,53%	98,02%	99,31%	99,59%	99,66%	99,55%	99,70%	99,80%	99,86%
Water Quality at the treatment works	Veekvaliteet puhastusjaamas	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Leakage in water network	Lekked veevõrgus	32,70%	32,40%	31,64%	29,57%	21,44%	17,95%	19,65%	19,58%	17,25%	17,51%	21,39%	17,73%	15,86%	16,97%	16,14%	14,68%
WASTEWATER COLLECTION AND TREATMENT	REOVEE KOGUMINE JA PUHASTAMINE																
Sewerage blockages	Kanaliseerimisvõrgu ummistused	2 136	2 080	1 638	1 654	1 356	1 404	1 397	1 435	1 336	1 089	1 152	944	715	761	733	737
<i>Suspended Solids %</i>	<i>Heijum %</i>	96,5	97,2	97,1	97,3	97,2	97,3	97,3	97,1	97,3	97,2	97,1	97,3	97,6	97,8	98	97,7
<i>Suspended Solids mg/l</i>	<i>Heijum mg/l</i>	8	7	8	8	8	9	9,7	9,6	9,1	9,2	10,5	9,3	7,4	6	5,9	7,1
<i>BOD 7 %</i>	<i>BHT 7 %</i>	97,9	97,6	97,8	98,2	97,6	97,9	98,1	98	98,1	98,2	98	98,3	98,2	98,1	98	97,7
<i>BOD 7 mg/l</i>	<i>BHT 7 mg/l</i>	3,5	4,1	3,9	3,7	3,9	4,2	4,4	3,9	3,7	3,7	4,1	3,3	3	3,3	3,5	3,9
<i>Oil products %</i>	<i>Naftasaadused %</i>	77	77,4	72,6	78,6	78,1	75,9	73,7	72,2	68,8	67,5	94,2	95,5	93,6	84,7	87,5	92,5
<i>Oil products mg/l</i>	<i>Naftasaadused mg/l</i>	0,6	0,5	0,6	0,6	0,7	0,7	0,5	0,5	0,5	0,4	0,02	0,02	0,04	0,09	0,06	0,05
<i>Total phosphorus %</i>	<i>Üldfosfor %</i>	75,2	82,4	83,9	85,3	84,8	86,7	87,8	85,2	84,3	85,2	85,8	85,3	86,3	92,3	93,1	93,1
<i>Total phosphorus mg/l</i>	<i>Üldfosfor mg/l</i>	1,29	0,96	0,97	0,98	0,87	0,9	0,92	0,94	0,96	0,97	0,97	0,92	0,76	0,45	0,47	0,43
<i>Total nitrogen % T>12°C</i>	<i>Üldlämmastik % T>12°C</i>	55,8	55,3	57,1	56,9	57,4	77,1	78,9	77,5	77,4	77,9	76,1	85,3	85	83,3	82,5	84,2
<i>Total nitrogen mg/l T>12°C</i>	<i>Üldlämmastik mg/l T>12°C</i>	13,3	14,8	15,5	17,2	13,8	10,1	9,7	9,1	9,9	10	11,9	6,4	5,6	7,5	8,2	8,2
Sewage sludge reused for compost or agriculture	Reoveesette taaskasutamine kompostiks ja haljastuseks	45%	28%	64%	81%	58%	65%	83%	104%	93%	100%	100%	100%	100%	100%	100%	100%
Sludge to Landfill	Reoveesette prügilasse ladustamine	-	72%	36%	19%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
WATER RESOURCES MANAGEMENT	VEERESSURSI HALDAMINE	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
CUSTOMER SERVICE	KLIENDITEENINDUS																
No of complaints	Kliendikaebuste arv	476	683	458	227	144	110	241	259	186	272	234	333	152	118	76	67